

西城校区化工 A 栋各排风系统排风量一览表

序号	新增管井 编号	管井尺寸 mm	服务排风 系统编号	管井内主风管尺寸 (mm)	最大排风量 (m³/h)	开孔个数
A 栋 A 区						
1	1#	2100*800	5PF-01	800*320	12210	2
2			6PF-02	800*320	8140	
3	2#	1200*800	6PF-02	800*630	20020	1
4	3#	1200*800	6PF-03	800*630	23100	1
5	4#	1200*800	6PF-04	800*630	20020	1
6	5#	1200*800	6PF-05	800*630	20020	1
7	6#	2100*800	5PF-03	630*630	16280	2
8			6PF-06	320*320	3630	
9	7#	1000*500	6PF-10	800*320	9240	1
A 栋 B 区						
1	8#	1000*700	2PF-03	Φ 315	3000	5
2			3PF-03	500*500	10200	
3	T1#	1200*700	6F	1000*500	18000 (预留风量)	1
4	T2#	1200*700	5F	1000*500	18000 (预留风量)	2
5	T3#	1200*700	4F	1000*500	18000 (预留风量)	3
6	T4#	1000*600	5F	800*400	12000 (预留风量)	2
7	T5#	1000*600	6F	800*400	12000 (预留风量)	1
8	T6#	1000*700	4F	800*500	15000 (预留风量)	3
9	T7#	1200*700	4F/5F/6F	1000*500	18000 (预留风量)	3
10	T8#	1200*700	4F/5F/6F	1000*500	18000 (预留风量)	3
11	T9#	1000*700	4F	800*500	15000 (预留风量)	3
12	T10#	1000*700	5F	800*500	15000 (预留风量)	2
13	T11#	1200*700	5F	1000*500	18000 (预留风量)	2
14	T12#	1200*700	6F	1000*500	18000 (预留风量)	1
15	T13#	1200*700	4F	1000*500	18000 (预留风量)	3
16	T14#	1200*700	6F	1000*500	18000 (预留风量)	1
A 栋 C 区						
1	9#	600*600	5PF-01	320*320	2900	3
2						
3	10#	800*600	7PF-01	630*400	10200	1
4	11#	800*600	7PF-02	630*400	10200	1
5	12#	800*600	7PF-03	630*400	10200	1
6	13#	800*600	7PF-04	630*400	15000	1
7	14#	1200*800	5PF-07	1000*630	25000	3
8						
9	15#	700*700	7PF-05	500*400	6800	1
10	16#	1200*800	4PF-06	1000*630	26000	4
11						
12	17#	1000*800	7PF-06	630*630	15000	1
13	18#	1000*800	7PF-07	800*630	20000	1
14	19#	1200*700	5PF-15	1000*500	26800	3
15						